



NOTES:

1. CONCRETE SHALL BE 3000 P.S.I.
2. TYPE OF PIPE TO BE USED IS : 2" O.D. GALVANIZED STEEL (SCHEDULE 40).
3. ALL JOINTS TO HAVE A 1/2" FILLET WELD AT ALL JOINTS.
4. HEIGHT OF HANDRAIL MAY BE REDUCED TO 42" IF NO BICYCLISTS WILL BE RIDING NEXT TO THE HANDRAIL.

NOT TO SCALE

## TYPICAL HANDRAIL INSTALLATION

CITY OF ROCKY MOUNT  
DEPT. OF ENGINEERING

APPROVED

-

STD. NO.

1.14

DATE

4-7-11

REVISION

-

REVISIONS

NO	DATE	DESCRIPTION