



Notes: 1. Concrete shall be Class B (2,500 psi min. compressive strength).

2. Concrete thickness shall be 6".

3. Refer to Std. Details 2.21-2.23 for construction of wheelchair ramp.

4. Where shown on plans, specified by Engineer, or existing subgrade must be removed due to soft, wet, frozen or yielding subgrade being encountered, #57 or #67 clean, washed stone bedding shall be provided, or CABC where shown on plans.



CONCRETE BUS SHELTER PAD - No Existing Sidewalk

DATE: December 19, 2012	STANDARD #: 1.20
APPROVED:	SHEET # 1 OF 1
REVISION:	