



NOTES:

1. BRICK OR CONCRETE PAVERS ALLOWED ONLY UNDER SPECIAL CONDITIONS.
2. THICKNESS OF BASE MAY VARY WITH SUBGRADE/TRAFFIC CONDITIONS. CHECK WITH CITY ENGINEER.
3. SCATTER SAND OR SCREENINGS OVER COMPLETED WORK AND SWEEP INTO CRACKS.
4. CONCRETE PAVERS SHOULD CONFORM TO THE REQUIREMENTS OF ASTM C-1319. BRICK PAVERS SHOULD CONFORM TO REQUIREMENTS OF ASTM C902-95.
5. EDGE RESTRAINT SHALL BE GALVANIZED STEEL OR ALUMINUM WITH 10" (250 MM) MIN. GALVANIZED SPIKES SPACED AT 12" TO 24" (300 MM - 600 MM.)

BRICK/CONCRETE PAVERS (LIGHT DUTY)

REVISIONS		
NO	DATE	DESCRIPTION

CITY OF ROCKY MOUNT
DEPT. OF ENGINEERING

APPROVED

DATE
02-20-03

STD. NO.

2.24
REVISION