



NOTES:

1. TAPS ON EXISTING VCP, CIP, AND DIP MAINS SHALL BE CUT USING AN APPROPRIATELY SIZED TAPPING MACHINE.
2. TAP SHALL BE SMOOTH AND CLEANED OF ALL FILINGS, BURS, DIRT, DEBRIS, ETC.
3. TAPPING SADDLE SHALL BE "STYLE CB" SEWER SADDLE AS MANUFACTURED BY ROMAC INDUSTRIES, INC. OR AN APPROVED EQUAL.

4" SERVICE CONNECTION ON EXIST. VCP, CIP, OR DIP MAIN

REVISIONS		
NO	DATE	DESCRIPTION

**CITY OF ROCKY MOUNT
DEPT. OF ENGINEERING**

APPROVED -
DATE 04-10-99

STD. NO. 4.15
REVISION -