



2500 P.S.I. CONCRETE  
CLASS B  
REQUIRED

NOMINAL DIAMETER	A	B	C	TRENCH WIDTH
6"	6"	1'0"	1'0"	2'6"
8"	10"	1'0"	1'0"	2'8"
12"	1'3"	1'0"	1'0"	3'0"
16"	1'8"	1'2"	1'2"	3'4"
20"	2'1"	1'2"	1'6"	3'8"
24"	2'6"	1'2"	1'10"	4'0"
30"	3'0"	1'4"	2'4"	4'6"

**BEND & BLOCKING OF 11 1/4° BENDS**

CITY OF ROCKY MOUNT  
DEPT. OF ENGINEERING

REVISIONS		
NO	DATE	DESCRIPTION

APPROVED	STD. NO.
-	5.20
DATE	REVISION
07-13-01	-