

**BID TABULATION
HV Circuit Breakers**

CLIENT: City of Rocky Mount

PROJECT: South POD Transformer Replacement

PROJECT NO.: 21-10329-8010

DATE: May 24 2022


1 2 3 4

BID SCHEDULE	Qty.	Power Tech	GE Energy	Mitsubishi	*** National Transformer Sales ***
Bid Security					N/A
BID SCHEDULE NO. 1 - Base Bid					
Power Circuit Breaker rated 6 kV nominal, 2,000 amperes continuous current carrying capacity at 60 Hertz with a minimum of 20,000 amperes symmetrical interrupting rating, furnished with current transformers, all as per Specification and attached Data Sheet.	1	NO BID	NO BID	NO BID	\$49,950.00
Delivery Charges	1				included
Sales Tax (if applicable)	1				-
TOTAL BASE BID					\$49,950.00
ALL BID SCHEDULES – Delivery Schedule					
Approval Drawings					8 weeks
Final Drawings					18 weeks
Delivery of Material					38-40 weeks
ALL BID SCHEDULES – Field Service Engineering (Per Day Rate)					
Per Day Rate (including expenses) for field service engineering for additional days					\$2,500.00
Rate per one round trip (including expenses) to the site:					\$4,000.00
MANUFACTURER		ABB	Alstom	Mitsubishi	Siemens

This is to certify that at **4:00 pm on Monday, May 16, 2022**, the bids tabulated herein were publicly opened, read, checked, and the above totals are correct. All recognized bids were accompanied by an acceptable check or bid bond. Any irregularities are noted under "Remarks."

Remarks:

*** recommended low evaluated bidder



05/24/2022

Michael Winkler, PE