


Vendor: _____

	City of Rocky Mount Addendum 1	
	Refer <i>ALL</i> Inquiries regarding this RFP to: Alicia Gaines Purchasing Associate III	RFP #320-070223AG – Preventative Maintenance on City Owned Generators 2023
		RFP Due Date: 3/3/2023
	Contract Type: Service	

FAILURE TO RETURN THIS ADDENDUM IN ACCORDANCE WITH INSTRUCTIONS MAY SUBJECT YOUR PROPOSAL TO REJECTION ON THE AFFECTED ITEM(S):

RFP Schedule Reminder

Event	Responsibility	Date and Time
Issue RFP	City	Friday, 2/17/2023
Submit Written Questions	Vendor	Wednesday, 2/22/2023
Provide Responses to Questions	City	Monday, 2/27/2023
Submit Proposals	Vendor	Friday, 3/3/2023 4:00 pm

Question and Answer

Question 1: It specifies in the Engine Tune-Up description: fuel timing and injection synchronization. Do you want these 2 things checked via the ECM (engine control module) or by removing the timing cover and checking by visual inspection with adjustments as needed?

Answer 1: Mechanical engines will need to be checked with the valve covers off. Electronic engines will require ECM verification.