



**City of Rocky Mount
Addendum 1**

Refer ALL Inquiries regarding this RFQ to:
Debra Harris
Purchasing Clerk

RFQ #320- 300621DH

RFQ Due Date: 8/16/2021

Contract Type: Services

RFQ Schedule Reminder

Action	Responsibility	Date/Time
Issue RFP	City	Wednesday 8/4/2021
Submit Written Questions/Question Deadline	Vendors	Tuesday 8/10/2021
Provide Response to Questions/Addendum	City	Thursday 8/12/2021
Submit Proposals	Vendors	Monday 8/16/2021 4:00 p.m.
Award Contract	City	TBD

Question and Answer

1. Once quantities have been acquired by contractor, is the city going to provide the quantities of hardware for the poles so fiber can be attached? No, this will be determined by the contractor and should be included in quote. The city will provide the fiber.
2. Is the City wanting any snowshoes installed for slack? Yes
3. Is the City wanting any canisters for splicing? No
4. Is the City wanting the spacing of the fiber to be from the electric neutral or from lower attachment on poles? Meet the NESC standards.
5. What is the minimum and maximum spacing distance required? It is 12" above existing comm lines. The city will adjust power to comply.
6. Are anchors with down guys or span guys required to back up dead ends? Yes
7. Is the City having fiber spliced by others? Yes