



"D"	CONCRETE ENCASEMENT "A"	LONGITUDINAL STEEL "X"
8"-10"	2' - 0"	8
12"-14"	2' - 6"	8
16"-18"	3' - 0"	12
20"-24"	3' - 6"	12

CREEK CROSSING ENCASEMENT DETAIL

REVISIONS		
NO	DATE	DESCRIPTION

CITY OF ROCKY MOUNT
DEPT. OF ENGINEERING

APPROVED
DATE
04-22-04

STD. NO.
4.22
REVISION