



NOTE: ALL DEAD END MAINS 6" & LARGER SHALL HAVE A FIRE HYDRANT AT ITS TERMINUS. IF LINE TERMINATION IS TEMPORARY, FIRE HYDRANT MAY BE RELOCATED WHEN LINE IS EXTENDED TO MEET SPACING REQUIREMENTS. A VALVE SHALL BE PLACED IN PLACE OF THE HYDRANT TEE FOR TESTING OF THE EXTENSION.

TEMPORARY LINE TERMINUS (6" & LARGER MAINS)

REVISIONS	
NO	DATE DESCRIPTION

CITY OF ROCKY MOUNT
DEPT. OF ENGINEERING

APPROVED
-
DATE
06-25-09

STD. NO.
5.3
REVISION
-