



NOTE:

1. VALVE BOX SHALL BE TELESCOPIC WITH SCREW TYPE ADJUSTMENT.
2. VALVE BOX SHALL BE CAST FROM ASTM A-48, CLASS 30 IRON & SHALL BE FULLY BITUMINOUS COATED FOR DIRECT BURIAL.
3. VALVE BOX SHALL BE VBX-TE-3B AS MANUFACTURED BY DEWEY BROTHERS, INC. OF GOLDSBORO, NC OR APPROVED EQUAL.
4. FOR INSTALLATION DETAILS, SEE STD. NO. 5.10.

STANDARD VALVE BOX

**CITY OF ROCKY MOUNT
DEPT. OF ENGINEERING**

REVISIONS		
NO	DATE	DESCRIPTION

APPROVED -	STD. NO. 5.9
DATE 04-07-00	REVISION -