



NOTE: 1. AIR RELEASE VALVE SHALL BE P-20 WITH VACUUM CHECK BY CRISPIN OR APPROVED EQUAL.

NOTE: 2. INSTALLATION OF THE AIR RELEASE MANHOLE SHALL BE IN THE SHOULDER, EXCEPT WHEN CONDITIONS REQUIRE INSTALLATION WITHIN THE ROADWAY.

## OFFSET AIR RELEASE VALVE AND MANHOLE ( 6" AND LARGER)

REVISIONS		
NO	DATE	DESCRIPTION

CITY OF ROCKY MOUNT  
DEPT. OF ENGINEERING

APPROVED  
-

DATE  
04-07-00

STD. NO.  
5.17

REVISION  
-