





SECTION



PLAN

2500 P.S.I. CONCRETE
CLASS B
REQUIRED

TEE	A	B	C
6"X6"X6"	2'0"	1'0"	1'0"
8"X8"X6"	2'0"	1'0"	1'0"
8"X8"X8"	2'4"	1'0"	1'6"
12"X12"X6"	2'4"	1'0"	1'6"
12"X12"X8"	2'6"	1'0"	1'6"
12"X12"X12"	2'8"	1'6"	1'10"
16"X16"X6"	2'6"	1'6"	1'10"
16"X16"X8"	2'6"	1'6"	1'10"
16"X16"X12"	2'10"	1'6"	2'0"
16"X16"X16"	2'10"	1'6"	2'0"
20"X20"X6"	2'6"	1'8"	2'2"
20"X20"X8"	2'6"	1'8"	2'2"
20"X20"X12"	2'10"	1'8"	2'2"
20"X20"X16"	2'10"	1'10"	2'2"

TEE	A	B	C
20"X20"X20"	3'2"	2'0"	3'0"
24"X24"X6"	2'6"	1'8"	2'6"
24"X24"X8"	2'6"	1'8"	2'6"
24"X24"X12"	2'10"	1'8"	2'6"
24"X24"X16"	2'10"	2'0"	3'0"
24"X24"X20"	3'2"	2'0"	3'0"
24"X24"X24"	3'6"	2'0"	3'6"
30"X30"X6"	2'6"	1'8"	3'4"
30"X30"X8"	2'6"	1'8"	3'4"
30"X30"X12"	2'10"	1'8"	3'4"
30"X30"X16"	3'6"	1'10"	3'8"
30"X30"X20"	3'6"	2'0"	3'8"
30"X30"X24"	3'10"	2'6"	4'0"
30"X30"X30"	4'2"	3'0"	4'4"

TRENCHING & BLOCKING OF TEES

REVISIONS		
NO	DATE	DESCRIPTION

CITY OF ROCKY MOUNT
DEPT. OF ENGINEERING

APPROVED -	STD. NO. 5.24
DATE 07-13-01	REVISION -