



WHEN CONNECTION TO THE CITY OF ROCKY MOUNT WATER DISTRIBUTION SYSTEM IS MADE FOR PURPOSE OF SUPPLYING SPRINKLER SYSTEMS AND STANDPIPES, THE FOLLOWING SHALL APPLY:

UPON INSTALLING A SPRINKLER OR STANDPIPE SYSTEM IN ANY NEW OR EXISTING BUILDING, ONE (1) FIRE HYDRANT SHALL BE LOCATED WITHIN SEVENTY-FIVE (75) FEET OF EACH STANDPIPE & SPRINKLER SYSTEM CONNECTION. AND, WHERE POSSIBLE, SUCH HYDRANTS SHALL BE LOCATED AT LEAST FIFTY (50) FEET FROM ANY BUILDING. ALL HYDRANTS MUST BE SERVED BY A WATER MAIN OF SUFFICIENT SIZE. IN NO CASE SHALL THE MINIMUM SIZE MAIN BE LESS THAN SIX (6) INCHES IN DIAMETER. ALL HYDRANTS & CONNECTIONS SHALL MEET CITY OF ROCKY MOUNT STANDARDS FOR HYDRANTS, CONNECTIONS, AND SHALL HAVE NATIONAL STANDARD THREADS.

## MINIMUM STANDARD FOR FIRELINE LAYOUT

REVISIONS			CITY OF ROCKY MOUNT DEPT. OF ENGINEERING	APPROVED	STD. NO.
NO	DATE	DESCRIPTION		-	5.27
				DATE	REVISION
				07-13-01	-